



Product Service

CERTIFICATE

No. Z1A 051686 0183 Rev. 02

Holder of Certificate: **CIXI DONGGONG ELECTRIC APPLIANCE CO., LTD.**

Guanhaiwei Industrial Zone(East section)
315314 Cixi, Ningbo, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Multiple Socket Outlets**

Tested according to: DIN VDE 0620-1:2021
DIN VDE 0620-2-1:2021/A1:2023
EK1 702-20 Rev.1
EK1 634-16 Rev.1
AfPS GS 2019:01 PAK

With this certificate, in its capacity as a notified GS body, TÜV SÜD Product Service GmbH issues the GS Mark to the named certificate holder for the declared product with the named model designation in accordance with section 20 ProdSG (German Product Safety Act). The product meets the safety and health requirements of section 20 (3) ProdSG. The manufacturer is reminded of their obligations in accordance with section 24 ProdSG. The certification marks shown above can be affixed on the product. It is not permitted to alter the certification marks in any way. In addition, the certificate holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 874102501932-00

Valid until: 2030-07-13

Date, 2025-07-14

(Ying Liu)

CERTIFICATE

No. Z1A 051686 0183 Rev. 02

Model(s): DG-DS04, DG-DSB04, DG-DS03K, DG-DSB03K
For model differences refer to Table 1

Parameters:

Rated voltage: 250V~
Rated current: 16A
Rated frequency: 50Hz
Protection class: I
Degree of protection: IP20
Type of cable: H05VV-F 3G1.5mm²

Table 1:

Model	Number of schuko socket-outlets	With switch	With shutter
DG-DS04	4	No	No
DG-DSB04	4	No	Yes
DG-DS03K	3	Yes	No
DG-DSB03K	3	Yes	Yes